

Certificate of Compliance

Certificate: 70156877

Master Contract: 204450

Project: 80250041

Date Issued: May 27, 2025

Issued to: Sun Yeh Electrical Ind.Co.,Ltd.
No 68 Lane 854, Sec.1, Shatian Rd.
Dadu Dist., Taichung City 432
Taiwan

Attention: Ms. Hsinhui Lin

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US (indicating that products have been manufactured to the requirements of both Canadian and US Standards) or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Issued by:


Eddie Lee

PRODUCTS

CLASS - 3228 02 VALVES-Actuators - For Hazardous Locations

CLASS - 3228 82 VALVES-Actuators - For Hazardous Locations-Certified to U.S. Standard

Class I, Division 1, Groups C, D T4

Class II, Division 1, Groups E, F, G T130°C

Type 4X

Ex db IIB T4 Gb (For Canada)

Class I, Zone 1, AEx db IIB T4 Gb (For US)

Ex tb IIIC T130°C Db (For Canada)

Zone 21, AEx tb IIIC T130°C Db (For US)

IP66, IP68 (72h, 7m)

OME Model Series Explosion-proof Quarter-Turn Actuators, rated 240 Vac max, 10.0 A max, $-30^{\circ}\text{C} \leq \text{Tamb} \leq 70^{\circ}\text{C}$, T4, Enclosure Type 4X, IP66 and IP68 (72h, 7m).

Where:

OME-X1-X2-X3-X4

OM stands for Quarter-Turn Actuator.

E stands for Explosion-proof.

X1 stands for type (1, A, AM, 2, 3, 4, 5, 6, 7, 8).

X2 stands for voltage (D12 stands for 12VDC, 12 stands for 12VAC, D24 stands for 24VDC, 24 stands for 24VAC, 100 stands for 100VAC, N=110 to 120 stands for one specific voltage among 110 ~ 120VAC, 200 stands for 200VAC, N=220 to 240 stands for one specific voltage among 220 ~ 240VAC).

X3 stands for controlling method (M stands for Modulating, F stands for Floating).

X4 Duty rating (%): 30, 75.

Duty cycle information

Models Series	Duty Cycle
OME-1, OME-A, OME-AM	30% (12 sec ON, 28 sec OFF), or 30% (20 sec ON, 46 sec OFF), or 75% (8 sec ON, 3 sec OFF), or 75% (12 sec ON, 4 sec OFF)
OME-2	30% (12 sec ON, 28 sec OFF), or 30% (15 sec ON, 35 sec OFF), or 75% (15 sec ON, 5 sec OFF)
OME-3	30% (15 sec ON, 35 sec OFF), or 30% (22 sec ON, 51 sec OFF), or 75% (22 sec ON, 7 sec OFF)
OME-4	30% (16 sec ON, 37 sec OFF), or 75% (16 sec ON, 5 sec OFF)
OME-5	30% (22 sec ON, 51 sec OFF), or 75% (22 sec ON, 7 sec OFF)
OME-6	30% (28 sec ON, 65 sec OFF), or 75% (28 sec ON, 9 sec OFF)
OME-7	30% (46 sec ON, 107 sec OFF), or 75% (46 sec ON, 15 sec OFF)
OME-8	30% (46 sec ON, 107 sec OFF), or 75% (46 sec ON, 15 sec OFF)

CONDITIONS OF ACCEPTIBILITY

1. The manufacturer recommends that any cable entry device used must maintain the IP rating of the enclosure.
2. The end user must ensure that any cable and cable entry devices used with the equipment are suitable for use at temperatures above 90°C.
3. The flamepaths in this equipment are different to the standard dimensions given in IEC 60079-1. If specific flamepath dimensions are required then the manufacturer (OEM) must be contacted.

APPLICABLE REQUIREMENTS

CSA C22.2 No. 30-M1986 <i>(Reaffirmed 2012)</i>	Explosion-Proof Enclosures for Use in Class I Hazardous Locations
CSA C22.2 No. 25-17 <i>July 2017</i>	Enclosures for Use in Class II, Division 1, Groups E, F, and G Hazardous Locations
CSA C22.2 No. 94.2-07	Enclosures for Electrical Equipment, Environmental Considerations
CSA C22.2 No. 139-10	Electrically Operated Valves
CAN/CSA-C22.2 No. 60079-0:15 <i>October 2015</i>	Explosive atmospheres – Part 0: Equipment – General requirements
CAN/CSA-C22.2 No. 60079-1:16 <i>May 2016</i>	Explosive atmospheres – Part 1: Equipment protection by flameproof enclosures “d”
CAN/CSA-C22.2 No. 60079-31:15 <i>Second Edition (October 2015)</i>	Explosive atmospheres - Part 31: Equipment dust ignition protection by enclosure “t”
FM 3600 <i>December 2011</i>	Approval Standard for Electrical Equipment for Use in Hazardous (Classified) Locations – General Requirements
FM 3615 <i>August 2006</i>	Approval Standard for Explosionproof Electrical Equipment General Requirements
FM 3616 <i>December 2011</i>	Approval Standard for Dust ignition proof Electrical Equipment General Requirements
ANSI/UL 50E <i>First Edition (September 4, 2007)</i>	Enclosures for Electrical Equipment, Environmental Considerations
UL 429 <i>Sixth Edition (November 11, 2009)</i>	Electrically Operated Valves
ANSI/UL 60079-0 <i>Six Edition (July 26, 2013)</i>	Explosive atmospheres – Part 0: Equipment – General requirements
ANSI/UL 60079-1 <i>Seventh Edition (September 18, 2016)</i>	Explosive Atmospheres – Part 1: Equipment Protection by Flameproof Enclosures “d”
ANSI/UL 60079-31 <i>Second Edition (2015.06.12)</i>	UL Standard for Safety Explosive Atmospheres – Part 31: Equipment Dust Ignition Protection by Enclosure “t”

MARKINGS

The manufacturer is required to apply the following markings:

- Products shall be marked with the markings specified by the particular product standard.
- Products certified for Canada shall have all Caution and Warning markings in both English and French.

Additional bilingual markings not covered by the product standard(s) may be required by the Authorities Having Jurisdiction. It is the responsibility of the manufacturer to provide and apply these additional markings, where applicable, in accordance with the requirements of those authorities.

The products listed are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US (indicating that products have been manufactured to the requirements of both Canadian and U.S. Standards) or with adjacent indicator 'US' for US only or without either indicator for Canada only.

For nameplate examples, see report excerpts for details.

Marking is silk-screened on a rivet secured metal plate(s)

The label description is as follows:

- Manufacturer's name: "Sun Yeh", or CSA Master Contract Number "204450", adjacent to the CSA Mark in lieu of manufacturer's name.
- Model number: As specified in the PRODUCTS section, above.
- Electrical ratings: As specified in the PRODUCTS section, above.
- Ambient temperature rating: As specified in the PRODUCTS section, above.
- Manufacturing date in MMY format, or serial number, traceable to year and month of manufacture.
- Enclosure ratings: As specified in the PRODUCTS section, above.
- The CSA Mark, as shown on the Certificate of Conformity.
- Hazardous Location designation: As specified in the PRODUCTS section, above.
- Method of Protection markings: As specified in the PRODUCTS section, above.
- Temperature code: As specified in the PRODUCTS section, above.
- The characters "CSA 18.70156877X" or "18.70156877X" when located adjacent to the CSA mark, designating the certification body, followed by the last two digits of the year of report issue, followed by a period, followed by the original report number, followed by the letter "X".
- The following or technically equivalent words:
 - o "OPEN CIRCUIT BEFORE REMOVING COVER" or "KEEP COVER TIGHT WHILE CIRCUITS ARE ALIVE" or equivalent.
 - o "SEAL REQUIRED WITHIN 18 INCHES(450 mm) OF ENCLOSURE" (for Divisions only)
 - o "SEAL REQUIRED WITHIN 2 INCHES (50 mm) OF ENCLOSURE" (for Zones only)
 - o "WARNING – AFTER DE-ENERGIZING, DELAY 10 MINUTES BEFORE OPENING"
 - o "CAUTION- USE FASTENERS WITH YIELD STRESS $\geq$ 450 MPa."

Notes:

Products certified under Class C322802 have been certified under CSA's ISO/IEC 17065 accreditation with the Standards Council of Canada (SCC). www.scc.ca





Supplement to Certificate of Compliance

Certificate: 70156877

Master Contract: 204450

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
80250041	May 27, 2025	To update CSA report 70156877 for : i. Model OME-1, OME-A, OME-AM Series, which are with 75% Modulating (24V / 110-120V / 220-240V, based on CSA ordinary location report 2689767-80152993 evaluated acceptance results, to alternate a proportional control board, SY-H215101. ii. Change protocol code from 432402 to 432 according to governmental arrangement.
80190137	February 29, 2024	Based on IECEx ExTR package to update CSA report 70156877 to: i. Postal code change from 43244 to 432403. ii. Warning plate change YIELD STRESS value from “ $\geq 700\text{MPa}$ ” to “ $\geq 450\text{Mpa}$ ”. iii. The right side of worm is changed from D-type to flat type, and the length is also adjusted from 116 mm to 113 mm, and from 40 mm to 43 mm. iiii. The right side of worm is changed from D-type to flat type, and the length is also adjusted from 26.5 mm to 29.5 mm. v. The right side of worm is changed from D-type to flat type, and the length is also adjusted from 33 mm to 37 mm. vi. Based on IECEx ExTR, 3X Hydrostatic Pressure Type Test complied test results, to allow Zone routine inspection can apply batch testing in the future. vi. Material change for the Handwheel from Plastic (N6) to ADC10. vii. For all Models to add IP66 ingress protection level aside HazLoc markings viii. To remove CAN/CSA C22.2 No.0 and CSA/UL 60529
80074859	Apr 27, 2021	Update Report 70156877 to correct typos of model names in duty cycle list.
80039653	July 10, 2020	Update report to: Expand voltage ratings. Change opening indicator and its cover. Change original manual base into with-position-indicator type. Update assembly drawings. Alternate the length of 4th driving shaft of OME-1 series and update drawing.
70183685	March 13, 2019	Update to report 70156877 for OME Model Series to add two alternate cement materials: SAUERISEN DW-30 and LOCTITE 5615.



Certificate:
Project:

Master Contract:
Date Issued:

70156877	May 30, 2018	Original certification of OME Model Series Explosion-proof Quarter-Turn Actuator models OME-1, OME-A, OME-AM, OME-2, OME-3, OME-4, OME-5, OME-6, OME-7, OME-8 series for use in Class I, Division 1, Groups C, D; Class II, Division 1, Groups E, F, G; Ex db IIB; Ex tb IIIC; Class I, Zone 1, AEx db IIB; and Zone 21, AEx tb IIIC hazardous locations.
----------	--------------	---