


- (1). "+" connects to 1, "-" connects to 7.
- (2). "-" connects to 3 for "OPEN", "-" connects to 4 for "CLOSE".
- (3). Using less than 5A current for "A,B,C,D,E,F".
- (4). Using battery to supply power for DC units.
- (5). Please wire terminal 7 as it is the power source for both power board and heater; otherwise, the actuator will not operate.



Rev 1.0	Signature	Date	OM2~OM6 · OMH Power Supply : 12VDC Floating Control 75% Duty Cycle
Designed			
Drawn	Guan Wei	2018/08/02	
Checked	Ming Hung	2018/09/01	
Approved			